

IMPORTANT SAFETY NOTICE

For Home Owners and Building Owners

Central Sprinkler to Replace 35 Million O-Ring Fire Sprinklers

Central Sprinkler Company, an affiliate of Tyco Fire Products LP of Lansdale, PA, and the U.S. Consumer Product Safety Commission (CPSC) are announcing a voluntary recall to replace approximately 35 million Central fire sprinklers with O-ring seals. A limited number of O-ring models sold by Gem Sprinkler Co. and Star Sprinkler, Inc., totaling about 167,000 sprinkler heads, are also included. *Under certain circumstances, these sprinklers may fail to activate in a fire.* These sprinklers were installed in a wide variety of buildings, including houses, apartments, hospitals, day care facilities, schools, dormitories, nursing homes, supermarkets, hotels, parking garages, warehouses and office buildings.



Example of "Wet" Sprinkler



Example of "Dry" Sprinkler

OBTAINING REPLACEMENTS

Central will provide free of charge replacement sprinkler heads and the labor needed to replace the sprinklers. The program will be phased in over time in an orderly process that best serves the public interest.

**For Help Identifying Your Sprinklers and to
Obtain Your Complete Notice Packet, Please Call:**

1-800-871-3492

(24 hours a day, 7 days a week)

or visit www.sprinklerreplacement.com